

**DAHA06-03-R-0012
UTES RENOVATIONS, East Lyme, Connecticut
AMENDMENT 004**

August 13, 2003

PROJECT EL0315 UTES RENOVATIONS

1. A question has arisen pertaining to the quantity of exterior wall mounted fixtures that have to be tested and repaired. The quantity of questionable fixtures can't be determined prior to bidding this project. Refer to the following;
 - a. SUMMARY OF WORK – DEMOLITION - NOTE #5 (ALTERNATE #1): “Remove exterior lighting fixtures that are broken or missing parts.”
 - b. DRAWING E1, NOTE #7: “Locate existing switch for building mounted exterior lighting. Test fixtures and repair as required. Mark electrical panel and switch. (Photos 31, 35, 47, 66, 72)”

RESPONSE: FOR BIDDING, Assume two (2) fixtures are damaged and will need replacement. The new fixtures shall match existing. The Bid shall include the purchase and installation of two (2) new fixtures and the location and marking of the panel box and switches.