DEPARTMENT OF THE ARMY
HEADQUARTERS, CONNECTICUT ARMY NATIONAL GUARD
CONSTRUCTION AND FACILITIES MANAGEMENT OFFICE
360 BROAD STREET
HARTFORD CONNECTICUT 06105-3795
(860) 493-2725 DSN 636-7725 FAX (860) 524-4937

CTDE-ENV (200-1A)

14 August 2003

MEMORANDUM FOR Facilities, ATTN: Ken Bergeron

SUBJECT: Asbestos testing of Bldg 5 roof at Stones Ranch

1. On July 29, 2003 the roof of building #5 at Stones Ranch Military Reservation was tested for the presence of asbestos containing materials. A copy of the results is enclosed. The full report is on file in the Environmental Office.

2. Asbestos was found in the following materials:
   - Gray flashing cement
     - Roof Perimeter – 528 sq ft 20-30% asbestos

3. The asbestos containing material does not have to be removed by a licensed abatement contractor, however any contractor must comply with OSHA regulations (29 CFR 1926.1101) to ensure worker protection.

4. Any asbestos containing material removed from this roof must be disposed of as Connecticut Special Waste. The environmental office should receive copies of documents showing that proper disposal procedures were followed,

5. If you have any questions or need assistance contact the undersigned at (860) 524-4945 or SPC Davis at (860) 493-2705.

THOMAS R. BORDNER
CPT, QM
Environmental Program Manager

CC:
LTC Kowal, TSSD (w/enclosure)
MAJ Lukowsi, FMO (w/enclosure)
CPT King, Health and Safety (w/enclosure)

"Facilities, The Foundation of Readiness"