

SOLICITATION W91ZRS-04-R-0011
Hartford Armory Security Upgrade
Amendment 001
August 18, 2004

Question: Is there any cable that will be needed for this project or if the enduser will be using the existing cable?

Answer: Cable will be required as follows:

Fixed cameras:

Video Transmission-RG59U plenum coax as manufactured by West Penn 25815 or equal.
Camera power-18 gauge 2 conductor shield with a drain wire as manufactured by West Penn 25293 or equal.

PTZ cameras: If camera distance exceeds 200 feet from power supply, provide local power supply for camera power

Video Transmission-RG59U plenum coax as manufactured by West Penn 25815 or equal.
Camera power-18 gauge 2 conductor shield with a drain wire as manufactured by West Penn 25293 or equal.
Ptz camera power- 14 gauge 2 conductor shield with a drain wire as manufactured by West Penn 25294 or equal.
Ptz data- 18 gauge 2 conductor shield with a drain wire as manufactured by West Penn 25293 or equal.